

The Water We Drink

MAGNOLIA-SHENANDOAH ESTATES

Public Water Supply ID: LA1055155

We are pleased to present to you the Annual Water Quality Report for the year 2025. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water system grade is an “A”. Our water system report card can be found at https://ldh.la.gov/assets/oph/Center-EH/drinkingwater/Watergrade/WaterGrade-2025/Lafayette/LA1055155_WaterGrade_2025.pdf

If you would like to review the Source Water Assessment Plan, please feel free to contact www.ldh.la.gov.

Our water source(s) are listed below:

Source Name	Source Water Type
PURCHASES FROM 1055193-BROUSSARD PURCHAS	Ground water
PURCHASES FROM 1055194-BROUSSARD HWY 90	Ground water
WELL #1	Ground water
WELL #2	Ground water

Our water system also purchases water as listed below:

Buyer Name	Seller Name
LA1055035 - CITY OF YOUNGSVILLE WATER SYSTEM	CITY OF BROUSSARD WATER SYSTEM
LA1055193 - CITY OF BROUSSARD PURCHASE WATER SYSTEM	LAFAYETTE UTILITIES WATER SYSTEM
LA1055194 - CITY OF BROUSSARD HWY 90 WATER SYSTEM	LAFAYETTE UTILITIES WATER SYSTEM
LA1055195 - CITY OF YOUNGSVILLE PURCHASE WS	LAFAYETTE UTILITIES WATER SYSTEM
LA1055196 - MILTON PURCHASE WATER SYSTEM	LAFAYETTE UTILITIES WATER SYSTEM
LA1055195 - CITY OF YOUNGSVILLE PURCHASE WS	CITY OF YOUNGSVILLE WATER SYSTEM
LA1055003 - CITY OF BROUSSARD WATER SYSTEM	CITY OF BROUSSARD PURCHASE WATER SYSTEM
LA1055194 - CITY OF BROUSSARD HWY 90 WATER SYSTEM	CITY OF BROUSSARD PURCHASE WATER SYSTEM
LA1055155 - MAGNOLIA-SHENANDOAH ESTATES	CITY OF BROUSSARD HWY 90 WATER SYSTEM
LA1055193 - CITY OF BROUSSARD PURCHASE WATER SYSTEM	CITY OF BROUSSARD HWY 90 WATER SYSTEM

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants – which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply want to learn more about your drinking water, please contact Magnolia UOC at 1-855-643-8152.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2025. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) – picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) – an enforceable procedure or level of technological performance which public water systems must follow to ensure control of a contaminant.

Action level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum contaminant level (MCL) – the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum contaminant level goal (MCLG) – the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG's allow for a margin of safety.

Maximum residual disinfectant level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Level 1 assessment – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

During the period covered by this report we had the below noted violations.

Compliance Period	Analyte	Type
9/1/2025 - 9/30/2025	CHLORINE	INADEQUATE MIN CHLORINE RESIDUAL(GW&SW)

Our water system tested a minimum of 1 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	HighestRAA	Unit	Range	MRDL	MRDLG	Typical Source
CHLORINE	2025	1.1	ppm	0.5 - 1.42	4	4	Water additive used to control microbes

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range	Unit	MCL	MCLG	Typical Source
ARSENIC	4/7/2025	LAFAYETTE UTILITIES WATER SYSTEM	1.5	0 - 1.5	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
ASBESTOS	1/6/2025	CITY OF YOUNGSVILLE WATER SYSTEM	5.93	0 - 5.93	MFL	7	7	Decay of asbestos cement water mains; Erosion of natural deposits
BARIUM	4/7/2025	LAFAYETTE UTILITIES WATER SYSTEM	0.26	0 - 0.26	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
BARIUM	2/5/2024	CITY OF YOUNGSVILLE WATER SYSTEM	0.27	0.23 - 0.27	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
BARIUM	1/9/2023	CITY OF BROUSSARD HWY 90 WATER SYSTEM	0.45	0.45	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

DI(2-ETHYLHEXYL) ADIPATE	11/26/2025	LAFAYETTE UTILITIES WATER SYSTEM	4.3	0 - 4.3	ppb	400	400	Discharge from chemical factories
FLUORIDE	6/5/2023	CITY OF BROUSSARD WATER SYSTEM	0.2	0.2	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
FLUORIDE	6/30/2025	LAFAYETTE UTILITIES WATER SYSTEM	0.2	0.2	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
FLUORIDE	4/15/2024	CITY OF YOUNGSVILLE WATER SYSTEM	0.3	0.2 - 0.3	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
FLUORIDE	1/9/2023	CITY OF BROUSSARD HWY 90 WATER SYSTEM	0.2	0.2	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE-NITRITE	7/14/2025	LAFAYETTE UTILITIES WATER SYSTEM	0.3	0 - 0.3	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	4/22/2025	CITY OF YOUNGSVILLE WATER SYSTEM	0.3	0.3	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	6/9/2025	CITY OF BROUSSARD HWY 90 WATER SYSTEM	0.2	0 - 0.2	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	1/31/2025	1.91	0 - 1.91	pCi/l	5	0	Erosion of natural deposits
COMBINED RADIUM (-226 & -228)	2/5/2024	1.193	0 - 1.193	pCi/l	5	0	Erosion of natural deposits
COMBINED RADIUM (-226 & -228)	1/9/2023	0.861	0.861	pCi/l	5	0	Erosion of natural deposits
GROSS ALPHA PARTICLE ACTIVITY	1/9/2023	1.52	1.52	pCi/l	15	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	6/5/2023	1.8	1.8	pCi/l	50	0	Decay of natural and man-made deposits.
GROSS BETA PARTICLE ACTIVITY	6/30/2025	2.12	0 - 2.12	pCi/l	50	0	Decay of natural and man-made deposits.
GROSS BETA PARTICLE ACTIVITY	2/5/2024	2.05	0 - 2.05	pCi/l	50	0	Decay of natural and man-made deposits.

GROSS BETA PARTICLE ACTIVITY	1/9/2023	4	4	pCi/l	50	0	Decay of natural and man-made deposits.
------------------------------	----------	---	---	-------	----	---	---

Lead and Copper	Date	90TH Percentile	Range	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2025	0.265	0 - 0.348	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2025	0.41	0 - 0.9	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	109 BULL RUN CIRCLE	2025	8	6.3	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	219 JANIN RD	2025	10	8.9	ppb	60	0	By-product of drinking water disinfection
TTHM	109 BULL RUN CIRCLE	2025	35	43.7	ppb	80	0	By-product of drinking water chlorination
TTHM	219 JANIN RD	2025	42	33.7	ppb	80	0	By-product of drinking water chlorination

Source Secondary Contaminants	Water System	Collection Date	Highest Value	Range	Unit	SMCL
ALUMINUM	CITY OF BROUSSARD WATER SYSTEM	6/5/2023	0.04	0.04	MG/L	0.2
ALUMINUM	LAFAYETTE UTILITIES WATER SYSTEM	6/30/2025	0.09	0.03 - 0.09	MG/L	0.2
ALUMINUM	CITY OF YOUNGSVILLE WATER SYSTEM	8/12/2024	0.05	0 - 0.05	MG/L	0.2
ALUMINUM	CITY OF BROUSSARD HWY 90 WATER SYSTEM	1/9/2023	0.03	0.03	MG/L	0.2
CHLORIDE	CITY OF BROUSSARD WATER SYSTEM	6/5/2023	31	31	MG/L	250
CHLORIDE	CITY OF YOUNGSVILLE WATER SYSTEM	2/5/2024	40	25 - 40	MG/L	250
CHLORIDE	CITY OF BROUSSARD HWY 90 WATER SYSTEM	1/9/2023	554	554	MG/L	250
HARDNESS, TOTAL (AS CaCO3)	CITY OF BROUSSARD WATER SYSTEM	6/5/2023	40.2	40.2	MG/L	0
HARDNESS, TOTAL (AS CaCO3)	LAFAYETTE UTILITIES WATER SYSTEM	4/7/2025	167	115 - 167	MG/L	0
HARDNESS, TOTAL (AS CaCO3)	CITY OF YOUNGSVILLE WATER SYSTEM	2/5/2024	54.5	45.4 - 54.5	MG/L	0
HARDNESS, TOTAL (AS CaCO3)	CITY OF BROUSSARD HWY 90 WATER SYSTEM	1/9/2023	53.4	53.4	MG/L	0

IRON	CITY OF BROUSSARD WATER SYSTEM	6/9/2025	0.23	0.23	MG/L	0.3
IRON	LAFAYETTE UTILITIES WATER SYSTEM	4/7/2025	1.49	0 - 1.49	MG/L	0.3
IRON	CITY OF BROUSSARD HWY 90 WATER SYSTEM	6/9/2025	0.08	0.03 - 0.08	MG/L	0.3
MANGANESE	CITY OF BROUSSARD WATER SYSTEM	6/9/2025	0.05	0.05	MG/L	0.05
MANGANESE	LAFAYETTE UTILITIES WATER SYSTEM	6/30/2025	0.18	0 - 0.18	MG/L	0.05
MANGANESE	CITY OF BROUSSARD HWY 90 WATER SYSTEM	6/9/2025	0.01	0 - 0.01	MG/L	0.05
PH	CITY OF BROUSSARD WATER SYSTEM	6/5/2023	7.81	7.81	PH	8.5
PH	LAFAYETTE UTILITIES WATER SYSTEM	6/30/2025	6.2	5.6 - 6.2	PH	8.5
PH	CITY OF YOUNGSVILLE WATER SYSTEM	2/5/2024	8.87	6.84 - 8.87	PH	8.5
PH	CITY OF BROUSSARD HWY 90 WATER SYSTEM	1/9/2023	6.82	6.82	PH	8.5
POTASSIUM	CITY OF BROUSSARD WATER SYSTEM	6/5/2023	1.9	1.9	MG/L	0
POTASSIUM	LAFAYETTE UTILITIES WATER SYSTEM	4/7/2025	1.5	0.9 - 1.5	MG/L	0
POTASSIUM	CITY OF YOUNGSVILLE WATER SYSTEM	2/5/2024	1.8	1.5 - 1.8	MG/L	0
POTASSIUM	CITY OF BROUSSARD HWY 90 WATER SYSTEM	1/9/2023	2.2	2.2	MG/L	0
SODIUM	CITY OF BROUSSARD WATER SYSTEM	6/5/2023	132.7	132.7	MG/L	0
SODIUM	LAFAYETTE UTILITIES WATER SYSTEM	4/7/2025	31.9	10 - 31.9	MG/L	0
SODIUM	CITY OF YOUNGSVILLE WATER SYSTEM	2/5/2024	143.2	97.3 - 143.2	MG/L	0
SODIUM	CITY OF BROUSSARD HWY 90 WATER SYSTEM	1/9/2023	406.8	406.8	MG/L	0
SULFATE	LAFAYETTE UTILITIES WATER SYSTEM	4/7/2025	5	0 - 5	MG/L	250

+++++Environmental Protection Agency Required Health Effects Language+++++
Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen

the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. MAGNOLIA-SHENANDOAH ESTATES is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact MAGNOLIA-SHENANDOAH ESTATES 1-855-643-8152. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

There are no additional required health effects notices.

There are no additional required health effects violation notices.

++++
Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.

We at the MAGNOLIA-SHENANDOAH ESTATES work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children's future. Additional information on the water system can be found at www.ldh.la.gov/watergrade. Please call our office if you have questions.

Please share this information with anyone who drinks this water (or their guardians), especially those who may not have received this report directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this report in a public place or distributing copies by hand, mail, email, or another method.