

*****IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER*****
Lincecum Water Powers Addition (TX0200159) Brazoria County, TX

LINCECUM WATER POWERS ADDITION PWS 0200159 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing (or did) to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During (52) 2ND 6M2023, we did not monitor or test for LCR and therefore cannot be sure of the quality of your drinking water during that time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for [these contaminants], how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which the follow-up samples were [or will be] taken.

| Contaminant | Required sampling frequency | Number of samples taken | When samples should have been taken | When samples were or will be taken |
|---|-----------------------------|-------------------------|--|---|
| <i>LCR Sample Tap 2ND 6M2023</i> | <i>5 / 6 months</i> | <i>0</i> | <i>JULY 1, 2023 – DEC 31, 2023</i> | <i>DATE: Prior to June 30, 2024</i> |

What is being done?

To return our system to compliance, we must collect a set of five tap samples between January 1, 2024, and June 30, 2024. These samples will be analyzed, and the results sent to the TCEQ by the July 10, 2024, deadline. All samples will be collected before June 30, 2024

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information, please contact Central States Water Resources Texas UOC Customer Experience by phone at 1-866-301-7725, by email at support@cswr texaswateruoc.com, or by mail at 1630 Des Peres Road, Suite 140, St. Louis, MO 63131.

This notice is being sent to you by: Lincecum Water Powers Addition
Public Water System ID: TX0200159

*****IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER***
Lincecum Water Powers Addition (TX0200159) Brazoria County, TX**

LINCECUM WATER POWERS ADDITION PWS 0200159 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the ground water system during (GWR): OCT 2023, monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples (raw water samples) are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active ground water well. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

What is being done?

To achieve compliance, a raw water sample from Well G0200159A was collected and analyzed. The results were submitted to the TCEQ, and as of 04/22/2024, CSWR-Texas has successfully returned this water system to compliance.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information, please contact Central States Water Resources Texas UOC Customer Experience by phone at 1-866-301-7725, by email at support@cswr texaswateruoc.com, or by mail at 1630 Des Peres Road, Suite 140, St. Louis, MO 63131.

This notice is being sent to you by: Lincecum Water Powers Addition
Public Water System ID: TX0200159

*****IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER***
Lincecum Water Powers Addition (TX0200159) Brazoria County, TX**

LINCECUM WATER POWERS ADDITION PWS 0200159 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Public water systems are required to collect and submit chemical samples of water provided to their customers and report the results of those samples to the TCEQ on a regular basis.

We failed to monitor and/or report the following constituent and Monitoring Periods: _

| <u>Constituent</u> | <u>Monitoring Period</u> |
|--------------------|--------------------------|
| <u>NITRATE</u> | <u>2023</u> |
| <u>SOC5</u> | <u>3yr2023</u> |
| <u>VOC</u> | <u>2023</u> |

Results of regular monitoring are an indicator of whether or not your drinking water is safe from chemical contamination. We did not complete all monitoring and/or reporting for chemical constituents, and therefore TCEQ cannot be sure of the safety of your drinking water during that time.

WHAT IS BEING DONE?

CSWR-Texas will have one of its operating and maintenance firms collect these samples before June 30, 2024. The results will then be submitted to TCEQ where results will be made available to the public

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information, please contact Central States Water Resources Texas UOC Customer Experience by phone at 1-866-301-7725, by email at support@cswrtexaswateruoc.com, or by mail at 1630 Des Peres Road, Suite 140, St. Louis, MO 63131.

**This notice is being sent to you by: Lincecum Water Powers Addition
Public Water System ID: TX0200159**