

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met For Gardner Water System (AZ0404038)

Our water system violated drinking water requirements from 2017-2021. Even though these were not emergencies, as our customers, you have a right to know what happened and what we are doing to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During compliance period of 2017-2021 we did not monitor for Lead & Copper and therefore, cannot be sure of the quality of your drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminants we did not properly test for during the compliance periods mentioned above, how often we are supposed to sample for these contaminants, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were taken
Lead & Copper	5 samples/triennially	0	2017-2019	The system has completed one round of 6-months sampling of 5 samples as of May 2022. Next sampling will take place in August 2022
Lead & Copper	5 samples/annually	0	2020	
Lead & Copper	5 samples/annually	0	2021	

What is being done?

During 2022, our monitoring frequency for Lead and Copper increased from 5 samples taken annually to 5 samples taken every 6 months. Our water system returned to compliance in May 2022 when we submitted all required Lead and Copper samples for the January 2022 - June 2022 monitoring period. We plan on sampling for the July 2022 - December 2022 monitoring period during August 2022.

For more information, please contact Yvonne Mazza at 303-981-3577 or email yvonne.mazza@jacobs.com

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Gardner Water System.
State Water System ID#: AZ0404038
Date distributed: 6/30/22