

## **IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

### **BOIL YOUR WATER BEFORE USING**

#### **Sunlight Acres 3421520 Well Tested Positive for Fecal Indicator**

Our water system recently detected a fecal indicator, Total Coliform and E-Coli, in our well. As our customers, you have a right to know what happened and what we are doing to correct this situation. On Friday, 08/25/2023, we learned that our assessment sample for the month of August were Total Coliform and E-Coli positive. As required by EPA's Ground Water Rule, one of our follow up steps is to collect additional samples from this well within 24 hours to determine the extent of the problem. This sampling will occur on Sunday, August, 27,2023.

#### **What should I do? What does this mean?**

**DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST.** Bring all water to a boil, let it boil for one minute, and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes, and food preparation until further notice. Boiling kills bacteria and other organisms in the water.

*Fecal indicators are microbes whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term health effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.*

The symptoms above are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice. People at increased risk should seek advice from their health care providers about drinking this water.

#### **What is being done?**

We will resample the well on Sunday, August 27, 2023. We will inform you when tests no longer show the presence of Total Coliform and E-Coli and you no longer need to boil your water. We will also provide information on any steps you should be taking, until this problem is corrected.

For more information, please contact Customer Support at CSWR Florida at 1-855-476-1942.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by CSWR Florida  
State Water System ID# 3421520 Date Sent:08/25/2023