

*****Important Information About Your Drinking Water*****

Branson Cedars Resort MO5282768

Failure to meet Nitrates Monitoring Requirements for drinking Water

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During January 01, 2022, to December 31, 2022, we did not monitor, or test as required and therefore cannot be sure of the quality of our drinking water during that time.

What Should I do?

There is nothing you need to do at this time.

The table lists the monitoring required by the system and the monitoring completed by the system.

Required Monitoring	Required Monitoring Frequency	Number of samples taken	When all samples should have been taken
Nitrates	2 per Year	1	December 31, 2022

What happened? What is being done?

The Confluence Rivers operations team failed to collect a sample from Well #2 during 2022. The required samples will be collected from Wells #1 and #2 during 2023 to return to compliance.

For more information, please contact Confluence Rivers Utility Operating Company, LLC at 1-866-945-3920 or 1630 Des Peres Road, Suite 140, Des Peres, MO 63131.

Additionally, you may contact the Missouri Department of Natural Resources Southwest Regional Office at 417-891-4300 or Public Drinking Water Branch at 573-526-6925.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by BRANSON CEDARS RESORT
State Water System ID# MO5282768