

ORIGINAL

Citrus Park Water Co
Docket No. W-03868A-00-0262

Eff: 1-1-01

RATE DESIGN

Monthly Usage Charge

	<u>RATES</u>
5/8" x 3/4" Meter	\$20.00
3/4" Meter	30.00
1" Meter	40.00
1 1/2" Meter	50.00
2" Meter	76.00
3" Meter	120.00
4" Meter	237.00
6" Meter	475.00

Gallage Charge - per 1,000 gallons 1.50

Service Line and Meter Installation Charges

(Refundable Pursuant to A.A.C. R14-2-405)

5/8" x 3/4" Meter	\$375.00
3/4" Meter	435.00
1" Meter	510.00
1 1/2" Meter	740.00
2" Meter	1,930.00
3" Meter	2,570.00
4" Meter	3,675.00
6" Meter	6,970.00

Service Charges

Establishment	\$25.00
Establishment (After Hours)	40.00
Reconnection (Delinquent)	25.00
Meter Test (If Correct)	20.00
Deposit	*
Deposit Interest	*
Re-Establishment (Within 12 Months)	**
NSF Check	15.00
Deferred Payment (Per Month)	1.50%
Meter Re-Read (If Correct)	10.00

Monthly Service Charge for Fire Sprinkler

4" or Smaller	***
6"	***
8"	***
10"	***

APPROVED FOR FILING
DECISION #: 63258

ORIGINAL

Larger than 10"

- * Per Commission Rules (R14-2-403.B)
- ** Months off system times the minimum (R14-2-403.D)
- *** 1.00% of monthly minimum for a comparable sized meter connection, but no less than \$5.00 per month. The service charge for fire sprinklers is only applicable for service lines separate and distinct from the primary water service line.

APPROVED FOR FILING

DECISION #: 63258

ORIGINAL

Company Name: Citrus Park Water Co. Page 1 of 2

CROSS-CONNECTION OR BACKFLOW TARIFF

PURPOSE:

The purpose of this tariff is to protect Citrus Park Water Co. (Company) water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code (A.A.C.) R14-2-405.B.6 and A.A.C. R18-4-115.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission (Commission) and the Arizona Department of Environmental Quality (ADEQ), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-115 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-115.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-115.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff.
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the device within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY****

**ADMINISTRATIVELY
APPROVED FOR FILING**

ORIGINAL

Effective Date: 1/15/01
Company Name: Citrus Park Water Co. Page 2 of 2

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-115.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location;
 - c. date(s) of tests(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
- 7A. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
- 8A. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

****FOR OFFICIAL USE ONLY****

Effective Date: Feb. 20, 2001

**ADMINISTRATIVELY
APPROVED FOR FILING**