

*****IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER*****
VERDE LEE WATER (AZ 0406004) Greenlee County
Has Levels of Arsenic Above Drinking Water Standards

Our water system **Verde Lee Water** recently exceeded a drinking water standard for levels of arsenic. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor the presence of many drinking water contaminants, including levels of arsenic. Testing results we received on December 20, 2024, show that our system exceeded the standard, or maximum contaminant level (MCL) for arsenic. The sample result was 23 parts per billion (ppb) and the standard for arsenic is 10 parts per billion (ppb). We are also required to calculate and measure the running annual average (RAA) (we essentially calculate the average of our arsenic sample results). The running annual average (RAA) for Arsenic is 17 parts per billion (ppb).

What does this mean?

This is not an emergency. If it had been, you would have been notified immediately. Some people who drink water containing arsenic in excess of the MCL over a period of many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer.

What should I do?

You do not need to use an alternative water supply (such as bottled water). However, if you have specific health concerns, please consult your doctor.

What is being done?

We have evaluated the arsenic treatment system to determine the reason why the system is not performing as it should in treating and removing arsenic from the drinking water. This includes reviewing procedures with our system operators and that process has been completed. On January 22nd, a contractor was on site to install additional arsenic treatment media to ensure the arsenic treatment system is functioning efficiently. We believe that our efforts will bring the system back into full compliance.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Cactus State Utility Operating Company for the Verde Lee Public Water System ID#: AZ0406004.