



SEBASTIAN LAKE

Utility Operating Company

A CSWR Managed Utility

*****Important Information About your Drinking Water*****
MCL Exceedance of Disinfection By-Products
Sebastian Lake AR0000511

The Sebastian Lake Utility Operating Company is a public water system subject to regulation of customers whenever a violation occurs and is the basis for this notice.

The annual average of quarterly samples of the level of total trihalomethanes, a disinfection by-product, in the water exceeded the maximum contaminant level of 80 parts per billion (ppb) for the period from January 2023 through March 2023. The average level in your water for site #511YD005 this period was 81 ppb.

The U.S. Environmental Protection Agency sets national standards for drinking water and has established the maximum level for Total Trihalomethanes at 80 micrograms per liter. Trihalomethanes are a group of by-product chemicals which are formed by the use of chlorine in the treatment of drinking water. Disinfectants, such as chlorine, react with naturally occurring organic and inorganic matter present in water to form chemicals called disinfection byproducts (DBPs). EPA has determined that a number of DBPs are health concern at certain levels of exposure.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. EPA has set standards to limit exposure to trihalomethanes, haloacetic acids and other DBPs.

The Arkansas Department of Health has advised the water system that there is no immediate health risk from consuming the water. Failure to meet this requirement does not mean that the water is unsafe or that alternate sources of water should be used,

This water system is reviewing available data and collecting additional information to determine the appropriate remedy. Should you have any questions concerning this notice, contact the water system at 1-866-270-4919 or the Engineering Section of the Department of Health at 501-661-2623.

Information on drinking water can be obtained from the Engineering Section at 501-661-2623 and on the health effects of Trihalomethanes from the Epidemiology Section at 501-280-4186.