



*****IMPORTANT INFORMATION ABOUT YOUR WATER SYSTEM*****
Maximum Contaminant Level (MCL) Violation, Running annual average –
Arsenic
Town North Village TX1520094

What happened?

The Texas Commission on Environmental Quality (TCEQ) has notified Town North Village (PWS ID# TX1520152) public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for arsenic.

The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for arsenic to be 0.010 milligrams per liter (mg/L) based on a running annual average (RAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for arsenic indicates a compliance value in the 3rd and 4th quarters of 0.011 mg/L for EP001.

What do I do?

This is not an emergency. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

What is being done?

Your water system is currently in receivership and CSWR-Texas Utility Operating Company is the temporary owner. CSWR is working closely with the TCEQ to ensure that all samples are taken and notices provided to customers.

Please share this information with all people who drink this water, especially those who may not have received this notice directly.

If you have questions regarding this matter or need a copy of this public notice in Spanish, you may contact CSWR-Texas UOC's Customer Support by calling 1-866-301-7725 or by email at support@cswr texaswateruoc.com.