

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Copano Ridge (TX0040029), Aransas County, TX
Treatment Technique Violation for October & November 2023

COPANO RIDGE SUBDIVISION TX0040029 has violated the treatment technique requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. During OCTOBER, NOVEMBER, AND DECEMBER 2023, sufficient levels of chlorine residual were not met in more than five percent (5%) of monthly samples.

We are taking the following actions to address this issue:

CSWR – Texas in collaboration with our Operation Partners have evaluated the situation and increased chlorination to properly meet the required chlorine residual target to ensure your water is disinfected and safe to drink.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.