



CACTUS STATE

Utility Operating Company

A CSWR Managed Utility

*****IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER*****
LOMA ESTATES AZ0413110 DRINKING WATER ADVISORY

Cactus State Utility Operating Company (Cactus State) is publishing this notice to inform customers about the detection of a Per- and Polyfluoroalkyl Substance (PFAS) **below** the U.S. Environmental Protection Agency (EPA) Maximum Contaminant Level (MCL) for PFAS in drinking water at the Loma Estates water system (AZ0413110).

In April 2024, the United States Environmental Protection Agency (EPA) finalized a National Primary Drinking Water Regulation establishing MCLs for six types of PFAS in drinking water: PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. While Arizona has no known manufacturers of PFAS chemicals, PFAS has been used in a variety of everyday products and product coatings since the early 1950s. Research indicates PFAS compounds were not used on large-scale industrial applications and tend to be localized near areas of potential frequent use.

On September 24, 2025, as part of the statewide PFAS monitoring program, the Arizona Department of Environmental Quality (ADEQ) conducted a routine test of the Loma Estates Water System. The laboratory reported a detection of PFOA slightly above laboratory detection limit, while still **below** the EPA MCL. PFBS and PFHxA were also detected at concentrations slightly above laboratory detection limits; however, EPA has not established a MCL for these constituents.

Chemical	EPDS001 PFAS Results (ppt) or HI Value	Maximum Contaminant Level (MCL)
EPA Method 537.1		
PFOA	1.97	4.0 ppt
PFOS	Not detected	4.0 ppt
PFNA	Not detected	10 ppt
PFHxS	Not detected	10 ppt
HFPO-DA (GenX chemicals)	Not detected	10 ppt
Mixture of two or more: PFHxS, PFNA, HFPO-DA, and PFBS	Not applicable	Hazard Index of 1

For more detailed information on PFAS, visit:

- <https://www.epa.gov/sdwa/and-polyfluoroalkyl-substances-pfas>
- https://azdeq.gov/PFAS_DW

For questions regarding the Loma Estates Water System, please contact Cactus State at 1-800-670-4869 or support@cactusstateuoc.com.

Date Distributed: