

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Timberlane Water System (TX2020054), Sabine, TX

TTHM (Total Trihalomethanes) Maximum Contaminant Level Violation Q3 (July - Sept) 2025

The Texas Commission on Environmental Quality (TCEQ) has notified the **Timberlane Public Water System** that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in **Q3 2025** of **0.118 mg/L** for **DBP2-01**.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

CSWR – Texas Utility Operating Company (UOC) has reviewed the potential causes of this water quality issue. To reduce the levels of disinfection by-products in your drinking water, we will be increasing system flushing. This helps keep water moving through the pipes, preventing stagnation that can contribute to the formation of these by-products.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Timberlane Water System (TX2020054), Sabine, TX
Monitoring & Reporting Violation for the Operational Evaluation Report

The TIMBERLANE WATER SYSTEM water system PWS ID TX2020054 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section §290, Subchapter F. Public water systems in exceedance of an operational evaluation level are required to conduct an evaluation of their source water, treatment and distribution operations and submit a report of their findings to the TCEQ.

We failed to conduct an operational evaluation and/or submit a report to the TCEQ.

This violation occurred in the monitoring period (April - June) quarter two, 2025.

We are taking the following actions to address this issue:

The Operational Evaluation Report was completed and submitted on Oct 23, 2025. This violation is resolved.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.