



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

ROY L UTILITIES Failure to Meet SYNTHETIC ORGANIC COMPOUNDS METHOD 507 Monitoring Requirements for Drinking Water

Este infonne contiene infonnaci6n muy importante sobre su agua potable. Traduzcalo o hable con alguien que lo entienda bien.

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards.

During **April 1, 2025 to June 30, 2025, and during January 1, 2026 to March 31, 2026** we did not monitor or test for **Synthetic Organic Compounds**, and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the monitoring required by the system and the monitoring completed by the system.

Required Monitoring	Required Monitoring Frequency	Number of samples taken	When all samples should have been taken
Synthetic Organic Compounds Method 507	1 per QT	Zero	June 30, 2025
Synthetic Organic Compounds Method 507	1 per QT	Zero	March 31, 2026

We are taking the following actions to address this issue:

The required Synthetic Organic Compounds (SOC) monitoring (Method 507), including atrazine, could not be completed as scheduled because the sample bottles were lost in transit. Replacement sample bottles have been requested, and the required sampling will be completed as soon as they are received.

Based on our historical monitoring results, SOC's have not been detected at concentrations exceeding the Maximum Contaminant Level (MCL) in our drinking water.

Once the replacement samples have been collected and analyzed, the results will be reviewed. If the monitoring identifies any results that require additional public notification, we will provide further notice.



CONFLUENCE RIVERS

Utility Operating Company

A CSWR Managed Utility

Confluence Rivers UOC can be reached via email or phone using the information at the bottom of this letter. Additionally, you may contact the Missouri Department of Natural Resources St Louis Regional Office at 314-416-2960 or Public Drinking Water Branch at 573-526-6925 if you have any questions or concerns.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: August 5, 2026



confluenceriversuoc.com



1-866-945-3920



support@confluenceriversuoc.com