CSWR-TEXAS
Utility Operating Company
A CSWR Managed Utility

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Cassie Water (TX0270047), Burnet County, TX
Surface Water Treatment Technique Violation, June 2026

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. You do not need to use an alternative water supply.

The CASSIE WATER SYSTEM, PWS ID TX0270047, failed to meet the minimum treatment technique requirements for the month of June 2026. Specifically, our water system failed to provide filtration.

We are taking the following actions to address this issue:

CSWR – Texas is in the process of installing additional treatment at this water system to ensure continued water quality, due to the groundwater well's proximity to surface water. Routine testing confirms that your drinking water currently meets all health standards and is safe to consume. If any future testing indicates a potential concern, you will be notified promptly.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: 10/30/2026